



## MFD Fireworks Stand Checklist

Met    Not met    N/A

### Tent located >20ft (Measured from tent stakes)

- Buildings
- Lot Lines
- Parking (drive lanes acceptable)
- Power lines
- Combustibles/trash
- Generators
- Fireworks storage


### Fireworks Separated by >100ft

- Fuel storage tanks
- Fuel tank vents
- Fueling pumps


### Signage

- Exit signs
- No smoking signs
- Flame resistance certificate provided
- Fireworks safety rules displayed


### Emergency Lighting

- Tents >3000 sq ft emergency lighting w/ battery backup 1 per exit
- Tents <3000 require flashlight at constantly attended location


### Fireworks

- Storage containers marked DOT Placard or "Fireworks" in 4" red letters
- 1.4G or UN 0336 or Consumer Fireworks
- No discharge within' 100 ft of tent
- Inventory list and Distributor License # \_\_\_\_\_


### Aisles and Exits

- Exits 6 ft minimum
- Aisles public 44" min
- Aisles employees 24" min
- Minimum 2 exits (<1000 sqft do not have to be remote)


### Electrical

- Connections off the ground
- Protected from wet location
- Protected from vehicle traffic


### Fire Extinguishers

- 0-500 sq ft 1 - 2A10BC or charged garden hose
- 501-1000 sq ft 2 - 2A10BC
- Each 2000 sq ft additional 1 - 2A10BC
- \*Fire extinguishers must have current service tag
